

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015418
DATE: 08/30/2021
CERTIFICATION PROGRAM: Structural
COMPANY: MP Windows
CODE: 2744-1

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
MP Windows, Inc 407 River Heights Circle Anderson, SC 29621	Series "T. B. L.M Impact" Aluminum Thermally-Broken Fixed Window Configuration: O Glazing: IG-3/16" Tempered Glass/3/16" Annealed Glass/0.090" Trosifol Interlayer by Kuraray/3/16" Annealed Glass Frame: W-1524mm(60") H-1524mm(60") DLO: W-1409mm(55.47") H-1356mm(53.4")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 AAMA/WDMA/CSA 101/I.S.2/A440-11 ASTM E1886-12/13a ASTM E1996-12a/14a	Class LC-PG55 1524 x 1524 (60 x 60)-FW Design Pressure: ±2640 Pa (±55 psf) Positive Design Pressure: 2880 Pa (60 psf) Negative Design Pressure: 2880 Pa (60 psf) Water Penetration Resistance Test Pressure: 580 Pa (12.00 psf) Impact Rating: Design Pressure: ±2640 Pa (±55 psf) Wind Zone 3 - Missile Level D

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-210-4209-2
Expiration Date: **June 30, 2025**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122