

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI015418-R1  
**DATE:** 08/30/2021  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** MP Windows  
**CODE:** 2744-1  
**REVISION DATE:** 01/21/2025

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<p><b>MP Windows, Inc</b>  <b>407 River Heights Circle</b>  <b>Anderson, SC 29621</b></p>	<p style="text-align: center;"><b>Series "T. B. L.M Impact" Aluminum</b>  <b>Thermally-Broken Fixed Window</b></p> <p style="text-align: center;">Configuration: O                      Glazing: IG-3/16" Tempered Glass/3/16" Annealed Glass/0.090"                      Trosifol Interlayer by Kuraray/3/16" Annealed Glass</p> <p>Frame:    W-1524mm(60")        H-1524mm(60")</p> <p>DLO:       W-1409mm(55.47")    H-1356mm(53.4")</p>

SPECIFICATION	PRODUCT RATING
<p><b>AAMA/WDMA/CSA 101/I.S.2/A440-17</b>  <b>AAMA/WDMA/CSA 101/I.S.2/A440-11</b>  <b>ASTM E1886-12/13a</b>  <b>ASTM E1996-12a/14a</b></p>	<p><b>Class LC-PG55 1524 x 1524 (60 x 60)-FW</b>  <b>Design Pressure: ±2640 Pa (±55 psf)</b>  <b>Positive Design Pressure: 2880 Pa (60 psf)</b>  <b>Negative Design Pressure: 2880 Pa (60 psf)</b>                      Water Penetration Resistance Test Pressure: 580 Pa (12.00 psf)</p> <p style="text-align: center;"><b>Impact Rating:</b>  <b>Design Pressure: ±2640 Pa (±55 psf)</b>  <b>Wind Zone 3 - Missile Level D</b></p>

Product Tested By: National Certified Testing Laboratories  
 Report No: NCTL-210-4209-2  
 Expiration Date: **June 30, 2029**

Administrator's Signature: \_\_\_\_\_

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
 Hayes, VA 23072  
 Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)

NOPC-03/30/2023