

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI011337.08-R2
DATE: 03/31/2021
CERTIFICATION PROGRAM: Structural
COMPANY: Ply Gem
CODE: 1408-1
REVISION DATE: 01/02/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Ply Gem Window Group 433 North Main Street Rocky Mount, VA 24151	"Ply Gem 1500 Integral Mull Twin" Twin Vinyl Fixed Window Configuration: OO Glazing: Insulating Glass (Annealed) Frame: W-1816mm(71.5") H-2121mm(83.5") DLO: W-787mm(31") H-2000mm(78.75")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08	Class LC-PG50 1829 x 2134* (72 x 84*)-FW Design Pressure: 2400 Pa (50 psf) Water Penetration Resistance Test Pressure: 360 (7.52 psf)

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-110-23170-1/NCTL-110-15589-1/W-2112
Expiration Date: **November 30, 2027**

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com