## **NOTICE OF PRODUCT CERTIFICATION =**



CERTIFICATION NO: NI012097.01

**DATE:** 09/07/2021

CERTIFICATION PROGRAM: <u>Structural</u>

COMPANY: Custom 2026-1

To verify that the "Notice of Product Certification" is valid, please visit <a href="www.NAMICertification.com">www.NAMICertification.com</a> to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Custom Millworks, Inc.	"Full Lite & 3/4" Lite French Doors"
7882 County Road 24	Impact Rated Wood Side Hinged Doors
Fairhope, AL 36532	
	Configuration: XX Glazing: Laminated-1/4" Tempered Glass/ 0.090" SGP interlayer by Kuraray/1/4" Tempered Glass
	Frame: W-1905mm(75") H-2489mm(98")
	Panel: W-914mm(36") H-2438mm(96")
	Max DLO: W-660mm(26") H-2083mm(82")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 AAMA/WDMA/CSA 101/I.S.2/A440-11 ASTM E1886-12/13a ASTM E1996-12a/14a	Class R-PG50 1905 x 2489 (75 x 98)-SHD  Design Pressure: ±2400 Pa (±50 psf)  Water Penetration Resistance Test Pressure: 360 Pa (7.50 psf)  Wind Zone 4-Missile Level D  Large Missile Impact Rated

Product Tested By: National Certified Testing Laboratories

Report No: NCTL-210-4161-01A Expiration Date: **February 28, 2025** 

Administrator's Signature:

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tol. (804) 684 5124

Tel: (804) 684-5124 Fax: (804) 684-5122