

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI012218.01-R1  
**DATE:** 01/04/2021  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Solar Innovations  
**CODE:** 872-1  
**REVISION DATE:** 06/23/2022

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Solar Innovations, Inc.</b> <b>31 Roberts Road</b> <b>Pine Grove, PA 17963</b>	<b>“SI3000”</b> <b>Aluminum Out-Fold Folding Glass Wall</b>  Configuration: XXXXXXX Glazing: Insulating Glass (Tempered)  Frame: W-5610mm(220.87") H-2362mm(93.00") Panel: W-904mm(35.62") H-2273mm(89.50") DLO: W-727mm (28.62") H-2095mm (82.50")

SPECIFICATION	PRODUCT RATING
<b>ASTM E283-04(12)/E330-14</b> <b>ASTM E331-00(09)/E547-00(09)</b>	<b>Design Pressure: 2640 Pa (55 psf)</b> <b>Negative Design Pressure: 2640 Pa (55 psf)</b> <b>Water Penetration Resistance Test Pressure: 192 Pa (4.0 psf)</b>

Product Tested By: National Certified Testing Laboratories, Inc.  
Report No: NCTL-110-17071-1/NCTL-110-17071-2  
Expiration Date: **May 31, 2026**

A handwritten signature in black ink, appearing to be 'Shelby' or similar, written over a horizontal line.

Administrator's Signature: \_\_\_\_\_

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
[nami@namiinc.com](mailto:nami@namiinc.com)