

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014949.05
DATE: 03/04/2021
CERTIFICATION PROGRAM: Structural
COMPANY: Sunrise Win.
CODE: 2483-1

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Sunrise Windows, LTD 200 Enterprise Drive Temperance, MI 48182	Series "Sunrise/Verde/Vanguard" Non-Impact Vinyl Sliding Glass Door (w/Standard Sill Riser) Configuration: XO Glazing: Insulating Glass (Tempered) Frame: W-2572mm(101.25") H-2442mm(96.13") Panel: W-1286mm(50.62") H-2364mm(93.06") DLO: W-1124mm(44.25") H-2165mm(85.25")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17	Class R-PG20 2572 x 2442 (101 x 96)-SD Design Pressure: ±958 Pa (±20 psf) Water Penetration Resistance Test Pressure: 215 Pa (4.5 psf)

Product Tested By: Testing Evaluation Laboratories
Report No: TEL 15502961
Expiration Date: April 30, 2024

Administrator's Signature: _____


NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122