

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015107.01-R1
DATE: 03/30/2021
CERTIFICATION PROGRAM: Structural
COMPANY: JELD-WEN
CODE: 1822-1
REVISION DATE: 06/23/2022

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
JELD-WEN 3737 Lakeport Boulevard Klamath Falls, OR 97601	Series "Auraline Composite 3-Panel" Composite Horizontal Sliding Window w/CHS Transom (Nail Fin or Thru Frame) Configuration: O/XOX Glazing: Insulating Glass (Annealed) Frame: W-1829mm(72") H-3042mm(119.75") Panel: W-457mm(18") H-1454mm(57.25") DLO: W-816mm(32.13") H-1365mm(53.75") Transom DLO:W-1746mm(38.75")H-1429mm(56.25")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08	Class LC-PG35 1829 x 3042 (72 x 120)-HS Design Pressure: 1680 Pa (35 psf) Positive Design Pressure: 1680 Pa (35 psf) Negative Design Pressure: 1920 Pa (40 psf) Water Penetration Resistance Test Pressure: 260 Pa (5.43 psf) Canadian Air Infiltration/Exfiltration Level: A3

Product Tested By: Intertek, PLC
Report No: L7742.01-301-47
Expiration Date: December 31, 2030

Administrator's Signature: _____ 

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124

Email: nami@namiinc.com