

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015108.01
DATE: 01/19/2021
CERTIFICATION PROGRAM: Structural
COMPANY: Domadeco
CODE: 2704-1

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

| COMPANY NAME AND ADDRESS | PRODUCT DESCRIPTION |
|---|---|
| Domadeco, Inc. 7455 Arroyo Crossing, Suite 220 Las Vegas, NV 89113 | Series "Outswing Entrance Door" Steel Opaque Single Outswing Side Hinged Door Configuration: X Frame: W-1003mm(39.50") H-2089mm(82.25") Panel: W-949mm(37.38") H-2048mm(80.63") |

| SPECIFICATION | PRODUCT RATING |
|--|--|
| AAMA/WDMA/CSA 101/I.S.2/A440-17 AAMA/WDMA/CSA 101/I.S.2/A440-11 ASTM E1886-13a/E1996-14a TAS 202-94 (Structural Only) TAS 201-94/TAS 203-94 | Class R-PG50 1003 x 2089 (39 x 82)-SHD Design Pressure: ±2400 Pa (±50 psf) Water Penetration Resistance Test Pressure: 0 Pa (0.00 psf) Wind Zone 4-Missile Level D Large Missile Impact Rated |

Product Tested By: Intertek, PLC
Report No: L2764.01-201-44/L2764.02-201-44/L2757.01-201-18
Expiration Date: August 31, 2024

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "S. D.", written over a horizontal line.

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122