

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI015131.01  
**DATE:** 12/21/2020  
**CERTIFICATION PROGRAM:** Man Housing  
**COMPANY:** Wausau Supply  
**CODE:** 1644-1

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Wausau Supply Company, Inc.</b> <b>8011 Technology Drive</b> <b>Schofield, WI 54476</b>	<b>Plastpro Opaque Fiberglass</b> <b>In-Swing Side Hinged Door</b>  Configuration: X  Frame: W-1880mm(74") H-2083mm(82") Panel: W-908mm(35.75") H-2013mm(79.25") STP: Pos+2777 Pa (58 psf) Neg-2777 Pa (58 psf)

SPECIFICATION	PRODUCT RATING
<b>AAMA 1702.2-95</b> <b>Federal Manufactured Home Construction</b> <b>&amp; Safety Standard 3280.405</b>	<b>Manufactured Housing-Passed</b> <b>Wind Zone III</b> <b>Design Wind Pressure Rating:</b> <b>+58/-58 psf</b>

Product Tested By: Testing Evaluation Laboratories, Inc.  
Report No: TEL 01391944  
Expiration Date: December 31, 2024

Administrator's Signature: \_\_\_\_\_  


**NATIONAL ACCREDITATION AND**  
**MANAGEMENT INSTITUTE, INC.**  
4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
Fax: (804) 684-5122