

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI015267.04  
**DATE:** 05/03/2021  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Endura  
**CODE:** 1353-1

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Endura Products, Inc.</b> <b>8817 West Market Street</b> <b>Colfax, NC 27235</b>	<b>Series "Plastpro Opaque Series" Inswing</b> <b>Opaque Fiberglass Side Hinged Door</b> <b>w/Panolock Multi-Point Lock</b>  Configuration: X  Frame: W-952mm (37.47") H-2488mm (97.94") Panel: W-908mm (35.75") H-2419mm (95.25")

SPECIFICATION	PRODUCT RATING
<b>ASTM E330/E330M-14</b> <b>ASTM E1886-13a</b> <b>ASTM E1996-14a</b>	<b>Design Pressure: +65/-65 psf</b> <b>Wind Zone 3 - Missile Level D</b>

Product Tested By: Molimo, LLC  
Report No: 2879.06-109-12/2533.01-109-12  
Expiration Date: April 30, 2025

Administrator's Signature: \_\_\_\_\_

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Fax: (804) 684-5122