

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015267.06-R1
DATE: 05/03/2021
CERTIFICATION PROGRAM: Structural
COMPANY: Endura
CODE: 1353-1
REVISION DATE: 05/13/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Endura Products, Inc. 8817 West Market Street Colfax, NC 27235	Series "Plastpro Opaque Series" Inswing Opaque Fiberglass Side Hinged Door w/Panolock Multi-Point Lock Configuration: XX Frame: W-1879mm (73.97") H-2488mm (97.94") Panel: W-908mm (35.75") H-2419mm (95.25")

SPECIFICATION	PRODUCT RATING
ASTM E330/E330M-14 ASTM E1886-13a ASTM E1996-14a	Design Pressure: +50/-50 psf Wind Zone 3 - Missile Level D

Product Tested By: Molimo, LLC
Report No: 2879.08-109-12/2533.01-109-12/W-2121
Expiration Date: April 30, 2025

A handwritten signature in black ink, appearing to be "M. D.", written over a horizontal line.

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

nami@namiinc.com

NOPC-03/30/2023