

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015267.07-R1
DATE: 05/03/2021
CERTIFICATION PROGRAM: Structural
COMPANY: Endura
CODE: 1353-1
REVISION DATE: 05/13/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

| COMPANY NAME AND ADDRESS | PRODUCT DESCRIPTION |
|---|--|
| Endura Products, Inc. 8817 West Market Street Colfax, NC 27235 | Series "Plastpro Opaque Series" Outswing Opaque Fiberglass Side Hinged Door w/Panolock Multi-Point Lock Configuration: XX Frame: W-1879mm (73.97") H-2467mm (97.13") Panel: W-908mm (35.75") H-2419mm (95.25") |

| SPECIFICATION | PRODUCT RATING |
|---|---|
| ASTM E330/E330M-14 ASTM E1886-13a ASTM E1996-14a | Design Pressure: +50/-50 psf Wind Zone 3 - Missile Level D |

Product Tested By: Molimo, LLC
Report No: 2879.09-109-12/2534.01-109-12/W-2121
Expiration Date: April 30, 2025

A handwritten signature in black ink, appearing to be 'Molimo'.

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

nami@namiinc.com

NOPC-03/30/2023