

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015267  
DATE: 05/03/2021  
CERTIFICATION PROGRAM: Structural  
COMPANY: Endura  
CODE: 1353-1

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Endura Products, Inc.</b> <b>8817 West Market Street</b> <b>Colfax, NC 27235</b>	<b>Series "Plastpro Opaque Series" Inswing</b> <b>Opaque Fiberglass Side Hinged Door</b> <b>w/Panolock Multi-Point Lock</b>  Configuration: X  Frame: W-952mm (37.47") H-2081mm (81.94") Panel: W-908mm (35.75") H-2013mm (79.25")

SPECIFICATION	PRODUCT RATING
<b>ASTM E330/E330M-14</b> <b>ASTM E1886-13a</b> <b>ASTM E1996-14a</b>	<b>Design Pressure: +65/-65 psf</b> <b>Wind Zone 3 - Missile Level D</b>

Product Tested By: Molimo, LLC  
Report No: 2879.02-109-12/2533.01-109-12  
Expiration Date: April 30, 2025

Administrator's Signature: \_\_\_\_\_

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
Fax: (804) 684-5122