## NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI015274.02-R1

**DATE:** 05/18/2021

CERTIFICATION PROGRAM: <u>Structural</u>

**COMPANY:** Endura

CODE: <u>1353-1</u>

**REVISION DATE:** 05/13/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit <a href="www.namicertification.com">www.namicertification.com</a>. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Endura Products, Inc.	<b>Inswing Opaque Fiberglass</b>
8817 West Market Street	Side Hinged Door
Colfax, NC 27235	w/Panolock Multi-Point Lock
	Configuration: XX
	Frame: W-1880mm (74") H-2083mm (82")
	Panel: W-908mm (35.75") H-2013mm (79.25")

SPECIFICATION	PRODUCT RATING
TAS 201/203-94 TAS 202-94	Design Pressure: +50/-55 psf Large Missile Impact Rated
(Structural only)	Zurge massie implies inten

Product Tested By: Testing Evaluation Laboratories

Report No: TEL 03853326/W-2121 Expiration Date: **April** 30, 2025

Administrator's Signature:

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway Hayes, VA 23072 Tel: (804) 684-5124

nami@namiinc.com