

NOTICE OF PRODUCT CERTIFICATION



Company: DW Distribution, Inc.
1220 Centre Park Boulevard
De Soto, TX 75115

Certification No.: NI015416.10
Certification Date: 08/30/2021
Expiration Date: 08/31/2025

Product: Fiberglass Glazed Inswing or Outswing Door w/ and w/o Non-Impact Rated Sidelites w/Endura Trilennium Multipoint Hardware(w/Wood Frame or Worldwide Composite Frame⁴ unless noted)

Specification: TAS 202-94/ASTM E330-02

Glazing: Insulating Glass (Tempered) Full-Lite Doors Require “HPC” Construction Slabs

The “Notice of Product Certification” is only valid if the NAMI Certification Label has been applied to the product as described within this document. The certification label represents product conformity to the applicable specification and that all certification criteria has been satisfied. This product has been approved for listing within NAMI’s Certified Product Listing at www.Namicertification.com. NAMI’s Certification Program is accredited by The American National Standards Institute (ANSI).

Configuration	Inswing or Outswing	Glazed or Opaque	Maximum Size	Structural Design Pressure	Water Test Pressure	Missile Impact Rated	Test Report Number Drawing Number & Comments
X Single	I/S	Glazed	3’0” x 6’8”	+50/-50	0.0 psf	No	ATLNC 0207.01-17/ATLNC 1012.01-16R/W-1814 Maximum Panel Size: 3’0” x 6’8” Anchor Details-DWG-MA-FL0201-17
X Single	O/S	Glazed	3’0” x 6’8”	+50/-50	3.75 psf ¹ 6.0 psf ² 8.25 psf ³ 9.0 psf ⁵	No	ATLNC 0207.01-17/ATLNC 1012.01-16R/W-1813/W-1814 Maximum Panel Size: 3’0” x 6’8” Anchor Details-DWG-MA-FL0201-17
XX Double	I/S	Glazed	6’0” x 6’8”	+50/-50	0 psf	No	ATLNC 0207.01-17/ATLNC 1012.01-16R/W-1814 Maximum Panel Size: 3’0” x 6’8” Anchor Details-DWG-MA-FL0201-17
XX Double	O/S	Glazed	6’0” x 6’8”	+50/-50	3.75 psf ¹ 6.0 psf ² 8.25 psf ³	No	ATLNC 0207.01-17/ATLNC 1012.01-16R/W-1813/W-1814 Maximum Panel Size: 3’0” x 6’8” Anchor Details-DWG-MA-FL0201-17
XO/OX Single w/Sidelite	I/S	Glazed	6’0” x 6’8”	+50/-50	0 psf	Door-No Sidelite-No	ATLNC 0207.01-17/ATLNC 1012.01-16R/W-1814 Maximum Panel Size: 3’0” x 6’8”/Sidelites: 3’0” x 6’8” Anchor Details-DWG-MA-FL0201-17
XO/OX Single w/Sidelite	O/S	Glazed	6’0” x 6’8”	+50/-50	3.75 psf ¹ 6.0 psf ² 8.25 psf ³ 9.0 psf ⁵	Door-No Sidelite-No	ATLNC 0207.01-17/ATLNC 1012.01-16R/W-1813/W-1814 Maximum Panel Size: 3’0” x 6’8”/Sidelites: 3’0” x 6’8” Anchor Details-DWG-MA-FL0201-17
OXO Single w/Sidelites	I/S	Glazed	9’0” x 6’8”	+50/-50	0 psf	Door-No Sidelites-No	ATLNC 0207.01-17/ATLNC 1012.01-16R/W-1814 Maximum Panel Size: 3’0” x 6’8”/Sidelites: 3’0” x 6’8” Anchor Details-DWG-MA-FL0201-17
OXO Single w/Sidelites	O/S	Glazed	9’0” x 6’8”	+50/-50	3.75 psf ¹ 6.0 psf ² 8.25 psf ³ 9.0 psf ⁵	Door-No Sidelites-No	ATLNC 0207.01-17/ATLNC 1012.01-16R/W-1813/W-1814 Maximum Panel Size: 3’0” x 6’8”/Sidelites: 3’0” x 6’8” Anchor Details-DWG-MA-FL0201-17
OXXO Double w/Sidelites	I/S	Glazed	12’4” x 6’8”	+50/-50	0 psf	Door-No Sidelites-No	ATLNC 0207.01-17/ATLNC 1012.01-16R/W-1814 Maximum Panel Size: 3’0” x 6’8”/Sidelites: 3’0” x 6’8” Anchor Details-DWG-MA-FL0201-17
OXXO Double w/Sidelites	O/S	Glazed	12’4” x 6’8”	+50/-50	3.75 psf ¹ 6.0 psf ² 8.25 psf ³ 9.0 psf ⁵	Door-No Sidelites-No	ATLNC 0207.01-17/ATLNC 1012.01-16R/W-1813/W-1814 Maximum Panel Size: 3’0” x 6’8”/Sidelites: 3’0” x 6’8” Anchor Details-DWG-MA-FL0201-17

1 -Denotes Bumper Outswing Threshold 2 -Denotes Z-Series Outswing Threshold 3-Hi-Dam Outswing Threshold 4-W-1815

National Accreditation & Management Institute, Inc./4794 George Washington Memorial Highway/Hayes, VA 23072

Tel: (804) 684-5124/Fax: (804) 684-5122

NAMI AUTHORIZED SIGNATURE: _____

A handwritten signature in black ink, appearing to be 'MJD', is written over the signature line.