NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO:	**NI015421.01**
DATE:	**09/01/2021**
CERTIFICATION PROGRAM:	**Structural**
COMPANY:	**United**
CODE:	**2779-1**

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
United Window & Door Manufacturing **24-36 Fadem Road** **Springfield, New Jersey 07081**	**Series "3900"** **Vinyl Single Hung Window** Configuration: O/X Glazing: Insulated Glass (Annealed) Frame: W-1118mm(44") H-1676mm(66") Sash: W-1041mm(41") H-781mm(31.88") DLO: W-997mm(39.25") H-749mm(29.50")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 **AAMA/WDMA/CSA 101/I.S.2/A440-11**	**Class R-PG30 1118 x 1676 (44 x 66)-H** **Design Pressure: ±1440 Pa (±30 psf)** **Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf)** **Canadian Infiltration/Exfiltration Level: A3**

Product Tested By: Molimo, LLC
Report No: 3099.03-109-12
Expiration Date: **August 31, 2025**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122