

NOTICE OF PRODUCT CERTIFICATION



| | |
|------------------------|--------------------|
| CERTIFICATION NO: | NI015423-R1 |
| DATE: | 09/08/2021 |
| CERTIFICATION PROGRAM: | Fire |
| COMPANY: | Benbilt |
| CODE: | 885-1 |
| EXPIRATION DATE: | 09/30/2029 |
| REVISION DATE: | 09/11/2025 |

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

| COMPANY NAME AND ADDRESS | PRODUCT DESCRIPTION |
|---|---|
| <p>BenBilt Building Systems</p> <p>123 Benbilt Place</p> <p>Greensburg, PA 15601</p> | <p>Taylor 90 Minute Steel</p> <p>Single Swing Side-Hinged Door</p> <p>w/Bayer Baytherm 3003 Core</p> <p>22 Gauge Steel Skin Door w/Bayer Baytherm 3003 Core for single swing installation in 90 Minute locations</p> <p>1/2" Minimum Latch Throw Single Swing Only</p> <p>Maximum Size: 3'0" x 6'8" 914mm x 2032mm</p> |

| SPECIFICATION | PRODUCT RATING |
|---|--|
| <p>NFPA 252 (2008)</p> <p>UL 10C (2009)</p> <p>CAN4 S104(1985)</p> | <p>90 Minute-Positive Pressure</p> <p>With Hose Stream</p> <p>Category B Door-Additional Edge Seal Required</p> <p>For Use in Category C Frame</p> |

| TEST REPORT |
|---|
| Intertek Test Report No: 3193924MID-007 |

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com