

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI015428  
**DATE:** 09/21/2021  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Valda  
**CODE:** 2773-1

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Valda 90 OOD</b> <b>5002 Western Industrial Zone</b> <b>Veliko Tarnovo, Bulgaria</b>	<b>Series "Vision"</b> <b>Vinyl Dual Action Window</b>  Configuration: X Glazing: Insulating Glass (Annealed) Frame: W-1219mm(48") H-1981mm(78") Vent: W-1092mm(43") H-1854mm(73") DLO: W-984mm(38.75") H-1746mm(68.75")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-17</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-11</b>	<b>Class CW-PG65 1219 x 1981 (48 x 78)-DAW</b> <b>Design Pressure: ±3120 Pa (±65 psf)</b> <b>Water Penetration Resistance Test Pressure: 468 Pa (9.75 psf)</b>

Product Tested By: National Certified Testing Laboratories  
Report No: NCTL-210-4220-02A  
Expiration Date: May 31, 2025

Administrator's Signature:  \_\_\_\_\_

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
Fax: (804) 684-5122