

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015429-R1
DATE: 09/22/2021
CERTIFICATION PROGRAM: Structural
COMPANY: Solar
CODE: 872-1
REVISION DATE: 04/10/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Solar Innovations, Inc. 31 Roberts Road Pine Grove, PA 17963	Series "G2 French Door" Impact Rated Aluminum Outswing Side Hinged Door w/Standard and HP Threshold Configuration: XX Glazing: IG-Ext.-3/16" Tempered Glass/Int.-Laminate 3/16" Annealed Glass/0.090" SentryGlas Plus Interlayer/3/16" Annealed Glass Frame: W-2032mm(80") H-2438mm(96") Panel: W-965mm(38") H-2378mm(93.63") DLO: W-791mm(31.13") H-2203mm(86.75")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 ASTM E1886-02/04/05/13a ASTM E1996-02/04/06/09/12a/14a	Class CW-PG40 2032 x 2438 (80 x 96)-SHD Design Pressure: ±1920 Pa (±40 psf) Water Penetration Resistance Test Pressure: 580 Pa(12.11 psf) Wind Zone 4-Missile Level D Large Missile Impact Rated

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-110-19487-1/NCTL-110-19488-1
Expiration Date: **September 30, 2028**

Administrator's Signature: 

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023