

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015434
DATE: 09/27/2021
CERTIFICATION PROGRAM: Structural
COMPANY: Valda
CODE: 2773-1

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Valda 90 OOD 5002 Western Industrial Zone Veliko Tarnovo, Bulgaria	Series "Vision Guard" Impact Rated Vinyl Dual Action Window Configuration: X Glazing: IG-Ext. 1/4" Tempered Glass/Int.-3/16" Annealed Glass/0.090"SGP interlayer by Kuraray/3/16" Annealed Glass Frame: W-1219mm(48") H-1981mm(78") Vent: W-1092mm(43") H-1854mm(73") DLO: W-984mm(38.75") H-1746mm(68.75")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 AAMA/WDMA/CSA 101/I.S.2/A440-11 ASTM E1886-12/13a ASTM E1996-12a/14a TAS 201/202/203-94	Class CW-PG65 1219 x 1981 (48 x 78)-DAW Design Pressure: ±3120 Pa (±65 psf) Water Penetration Resistance Test Pressure: 468 Pa (9.75 psf) Wind Zone 4 - Missile Level D Large Missile Impact Rated

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-210-4218-02A/NCTL-210-4218-02
Expiration Date: **May 31, 2025**

Administrator's Signature: _____ 

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122