

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015441-R1
DATE: 09/30/2021
CERTIFICATION PROGRAM: Structural
COMPANY: Shanghai
CODE: 2590-1
REVISION DATE: 11/18/2021

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Shanghai Superhouse Building Material Co., LTD Number 10, Hangfan Road Pudong New Area, Shanghai China 201314	Series "SP100T" Aluminum Outswing Side Hinged Door Configuration: X Glazing: Insulating Glass (Tempered) Frame: W-900mm(35.43") H-2400mm(94.49") Panel: W-811mm(31.93") H-2311mm(90.98") DLO: W-654mm(25.75") H-2154mm(84.80")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17	Class R-PG40 900 x 2400 (35 x 94)-SHD Design Pressure: ±1920 Pa (±40 psf) Water Penetration Resistance Pressure: 290 Pa (6.06 psf)

Product Tested By: Intertek - Shanghai
Report No: 210713011SHF-004
Expiration Date: August 31, 2031

Administrator's Signature: 

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com