

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI015447  
**DATE:** 10/05/2021  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** CGI Impact  
**CODE:** 2750-1

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>CGI Impact Resistant Windows &amp; Doors</b> <b>3780 West 104<sup>th</sup> Street</b> <b>Hialeah, FL 33018</b>	<b>Series "HR3110V" Impact Rated</b> <b>Vinyl Horizontal Slider</b>  Configuration: XOX Glazing: IG-Exterior-1/8" Annealed or 1/8" Tempered Glass/Interior-Laminate-1/8" Annealed/0.045" Trosifol PVB by Kuraray/1/8" Annealed OR IG-Exterior-1/8" Annealed or 1/8" Tempered Glass/Interior-Laminate-1/8" Heat Strengthened/0.045" Trosifol PVB by Kuraray/1/8" Heat Strengthened  Frame: W-2819mm(111") H-1372mm(54") Vent: W-710mm(27.94") H-1310mm(51.56") DLO: W-1294mm(50.94") H-1292mm(50.88")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-17</b> <b>ASTM E1886-13a/19</b> <b>ASTM E1996-17/20</b>	<b>Class R-PG50 2819 x 1372 (111 x 54)-HS</b> <b>Design Pressure: ±2400 Pa (±50 psf)</b> <b>Water Penetration Resistance Test Pressure: 360 Pa (7.5 psf)</b> <b>Wind Zone 2 - Missile Level C</b>

Product Tested By: Fenestration Testing Laboratory, Inc.

Report No: 21-1064

Expiration Date: March 31, 2025

Administrator's Signature: \_\_\_\_\_ 

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Fax: (804) 684-5122