

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015448
DATE: 10/12/2021
CERTIFICATION PROGRAM: Structural
COMPANY: Shangdong Lvdun
CODE: 2785-1

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

| COMPANY NAME AND ADDRESS | PRODUCT DESCRIPTION |
|---|--|
| Shangdong Lvdun Doors and Windows Co., LTD 7027 Dongtai Road, Dongcheng Street Linqu County, Weifang City, Shandong Province, China 262600 | Series "76" Aluminum Dual-Action Window & Fixed Window Assembly Configuration: OX Glazing: Insulating Glass (Tempered) Frame: W-2654mm(104.49") H-1850mm(72.83") Panel: W-1154mm(45.43") H-1785mm(70.28") DLO: W-1333mm(52.48") H-1764mm(69.45") |

| SPECIFICATION | PRODUCT RATING |
|--|---|
| AAMA/WDMA/CSA 101/I.S.2/A440-17 A440S1-17 | Class LC-PG50 2654 x 1850 (104 x 73)-DAW Design Pressure: ±2400 Pa (±50 psf) Water Penetration Resistance Pressure: 360 Pa (7.52 psf) Canadian Air Infiltration/Exfiltration Level: A2/Fixed |

Product Tested By: Intertek - Shanghai
Report No: 210812008SHF-001
Expiration Date: September 30, 2025

Administrator's Signature: 

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122