

NOTICE OF PRODUCT CERTIFICATION



Company: Millsource Inc. dba Woodgrain Distribution
 510 Hester Drive
 White House, TN 37188

Certification No.: NI015451-R1
Certification Date: 10/25/2021
Expiration Date: 10/31/2027
Revision Date: 10/13/2025

Product: Therma-Tru FiberClassic/Smooth Star Glazed Fiberglass Door Inswing/Outswing w/ and w/o Sidelites

Specification: ASTM E330

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

Configuration	Inswing or Outswing	Glazed or Opaque	Maximum Size	Design Pressure Pos/Neg	Missile Impact Rated	Test Report Number & Comments
X Single	I/S	Glazed	3'0" x 8'0"	+47/-47	No	NCTL-210-1940-1.2.3.4/TTF-257F
X Single	O/S	Glazed	3'0" x 8'0"	+47/-47	No	NCTL-210-1940-1.2.3.4/TTF-257F
XX Double	I/S	Glazed	6'0" x 8'0"	+40/-40	No	NCTL-210-1940-1.2.3.4/TTF-257F Standard Aluminum Astragal
XX Double	O/S	Glazed	6'0" x 8'0"	+40/-40	No	NCTL-210-1940-1.2.3.4/TTF-257F Standard Aluminum Astragal
XX Double	I/S	Glazed	6'0" x 8'0"	+47/-47	No	NCTL-210-1940-1.2.3.4/TTF-257F Coastal Aluminum Astragal
XX Double	O/S	Glazed	6'0" x 8'0"	+47/-47	No	NCTL-210-1940-1.2.3.4/TTF-257F Coastal Aluminum Astragal
OXO/OX/XO Single w/Sidelites	I/S	Glazed Door Glazed Sidelites	5'4" x 8'0"	+40/-40	No	ETC-01-741-10593.0/L-2173/TTF-257F
OXO/OX/XO Single w/Sidelites	O/S	Glazed Door Glazed Sidelites	5'4" x 8'0"	+40/-40	No	ETC-01-741-10593.0/L-2173/TTF-257F
OXXO Double w/Sidelites	I/S	Glazed Door Glazed Sidelites	8'4" x 8'0"	+40/-40	No	ETC-01-741-10593.0/L-2173/TTF-257F Standard Aluminum Astragal
OXXO Double w/Sidelites	O/S	Glazed Door Glazed Sidelites	8'4" x 8'0"	+40/-40	No	ETC-01-741-10593.0/L-2173/TTF-257F Standard Aluminum Astragal
OXXO Double w/Sidelites	I/S	Glazed Door Glazed Sidelites	8'4" x 8'0"	+47/-47	No	ETC-01-741-10593.0/L-2173/TTF-257F Coastal Aluminum Astragal
OXXO Double w/Sidelites	O/S	Glazed Door Glazed Sidelites	8'4" x 8'0"	+47/-47	No	ETC-01-741-10593.0/L-2173/TTF-257F Coastal Aluminum Astragal

National Accreditation & Management Institute, Inc./4794 George Washington Memorial Highway/Hayes, VA 23072

Tel: (804) 684-5124/Email: nami@namiinc.com

NAMI AUTHORIZED SIGNATURE: _____