

# NOTICE OF PRODUCT CERTIFICATION



**Company:** Millsource Inc. dba Woodgrain Distribution  
 510 Hester Drive  
 White House, TN 37188

**Certification No.:** NI015452-R1  
**Certification Date:** 10/25/2021  
**Expiration Date:** 10/31/2027  
**Revision Date:** 10/13/2025

**Product:** Therma-Tru FiberClassic Opaque Fiberglass Door Inswing/Outswing w/ and w/o Sidelites

**Specification:** ASTM E330/E331/TAS202

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

Configuration	Inswing or Outswing	Glazed or Opaque	Maximum Size	Design Pressure Pos/Neg	Missile Impact Rated	Test Report Number & Comments
X Single	I/S	Opaque	3'0" x 8'0"	+67/-67	No	ETC-01-741-10703.0/L-2097/TTF-253F
X Single	O/S	Opaque	3'0" x 8'0"	+67/-67	No	ETC-01-741-10703.0/L-2097/TTF-254F
XX Double	I/S	Opaque	6'0" x 8'0"	+40/-40	No	ETC-01-741-10703.0/L-2097/TTF-253F Standard Aluminum Astragal
XX Double	O/S	Opaque	6'0" x 8'0"	+40/-40	No	ETC-01-741-10703.0/L-2097/TTF-254F Standard Aluminum Astragal
XX Double	I/S	Opaque	6'0" x 8'0"	+47/-47	No	ETC-01-741-10703.0/L-2097/TTF-253F Coastal Aluminum Astragal
XX Double	O/S	Opaque	6'0" x 8'0"	+47/-47	No	ETC-01-741-10703.0/L-2097/TTF-254F Coastal Aluminum Astragal
OXO/OX/XO Single w/Sidelites	I/S	Opaque Door Glazed Sidelites	5'4" x 8'0"	+40/-40	No	ETC-01-741-10593.0/L-2097/TTF-253F
OXO/OX/XO Single w/Sidelites	O/S	Opaque Door Glazed Sidelites	5'4" x 8'0"	+40/-40	No	ETC-01-741-10593.0/L-2097/TTF-254F
OXXO Double w/Sidelites	I/S	Opaque Door Glazed Sidelites	8'4" x 8'0"	+40/-40	No	ETC-01-741-10593.0/L-2097/TTF-253F Standard Aluminum Astragal
OXXO Double w/Sidelites	O/S	Opaque Door Glazed Sidelites	8'4" x 8'0"	+40/-40	No	ETC-01-741-10593.0/L-2097/TTF-254F Standard Aluminum Astragal
OXXO Double w/Sidelites	I/S	Opaque Door Glazed Sidelites	8'4" x 8'0"	+47/-47	No	ETC-01-741-10593.0/L-2097/TTF-253F Coastal Aluminum Astragal
OXXO Double w/Sidelites	O/S	Opaque Door Glazed Sidelites	8'4" x 8'0"	+47/-47	No	ETC-01-741-10593.0/L-2097/TTF-254F Coastal Aluminum Astragal

National Accreditation & Management Institute, Inc./4794 George Washington Memorial Highway/Hayes, VA 23072  
 Tel: (804) 684-5124/Email: [nami@namiinc.com](mailto:nami@namiinc.com)

NAMI AUTHORIZED SIGNATURE: \_\_\_\_\_