

NOTICE OF PRODUCT CERTIFICATION



Company: Millsource Inc. dba Woodgrain Distribution
510 Hester Drive
White House, TN 37188

Certification No.: NI015454-R1
Certification Date: 10/25/2021
Expiration Date: 10/31/2027
Revision Date: 10/13/2025

Product: Therma-Tru Premium Series Wood Edge Opaque Steel Door Inswing/Outswing w/ and w/o Sidelites

Specifications Tested To: ASTM E330/E331/TAS201/202/203

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

Configuration	Inswing or Outswing	Glazed or Opaque	Maximum Size	Design Pressure Pos/Neg	Missile Impact Rated	Test Report Number & Comments
X Single	I/S	Opaque	3'0" x 6'8"	+75/-75	Yes	ETC-01-741-10639.0/PSI-202F/L-2150
X Single	O/S	Opaque	3'0" x 6'8"	+75/-75	Yes	ETC-01-741-10639.0/PSI-202F/L-2150
XX Double	I/S	Opaque	6'0" x 6'8"	+40/-40	Yes	ETC-01-741-10639.0/PSI-202F/L-2150 Standard Aluminum Astragal
XX Double	O/S	Opaque	6'0" x 6'8"	+40/-40	Yes	ETC-01-741-10639.0/PSI-202F/L-2150 Standard Aluminum Astragal
XX Double	I/S	Opaque	6'0" x 6'8"	+65/-65	Yes	ETC-01-741-10639.0/PSI-202F/L-2150 Coastal Aluminum Astragal
XX Double	O/S	Opaque	6'0" x 6'8"	+65/-65	Yes	ETC-01-741-10639.0/PSI-202F/L-2150 Coastal Aluminum Astragal
O XO/O X/XO Single w/Sidelites	I/S	Opaque Door Glazed Sidelites	5'4" x 6'8"	+65/-65	Door-Yes Sidelites-No	ETC-01-741-11006.0.0/PSI-202F/L-2149
O XO/O X/XO Single w/Sidelites	O/S	Opaque Door Glazed Sidelites	5'4" x 6'8"	+65/-65	Door-Yes Sidelites-No	ETC-01-741-11006.0.0/PSI-202F/L-2149
O X X O Double w/Sidelites	I/S	Opaque Doors Glazed Sidelites	8'4" x 6'8"	+40/-40	Doors-Yes Sidelites-No	ETC-01-741-11006.0.0/PSI-202F/L-2149 Standard Aluminum Astragal
O X X O Double w/Sidelites	O/S	Opaque Doors Glazed Sidelites	8'4" x 6'8"	+40/-40	Doors-Yes Sidelites-No	ETC-01-741-11006.0.0/PSI-202F/L-2149 Standard Aluminum Astragal
O X X O Double w/Sidelites	I/S	Opaque Doors Glazed Sidelites	8'4" x 6'8"	+65/-65	Doors-Yes Sidelites-No	ETC-01-741-11006.0.0/PSI-202F/L-2149 Coastal Aluminum Astragal
O X X O Double w/Sidelites	O/S	Opaque Doors Glazed Sidelites	8'4" x 6'8"	+65/-65	Doors-Yes Sidelites-No	ETC-01-741-11006.0.0/PSI-202F/L-2149 Coastal Aluminum Astragal

National Accreditation & Management Institute, Inc./4794 George Washington Memorial Highway/Hayes, VA 23072

Tel: (804) 684-5124/Email: nami@namiinc.com

NAMI AUTHORIZED SIGNATURE: _____