

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI015394.04  
**DATE:** 12/09/2021  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** United  
**CODE:** 2779-1

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>United Window &amp; Door Manufacturing</b> <b>24-36 Fadem Road</b> <b>Springfield, New Jersey 07081</b>	<b>Series "5800/5900"</b> <b>Vinyl Double Hung Window</b>  Configuration: X/X Glazing: Insulated Glass (Annealed)  Frame: W-902mm(35.50") H-1664mm(65.50") Sash : W-826mm(32.50") H-816mm(32.13") DLO: W-765mm(30.13") H-754mm(29.69")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-17</b>	<b>Class R-PG50 902 x 1664* (36 x 66*)-H</b> <b>Design Pressure: ±2400 Pa (±50 psf)</b> Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf)

Product Tested By: Molimo, LLC  
Report No: 11066.04-106-12/2316.04-106-12  
Expiration Date: November 30, 2025

Administrator's Signature: \_\_\_\_\_  


## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)