

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015477
DATE: 12/14/2021
CERTIFICATION PROGRAM: Structural
COMPANY: CGI Impact
CODE: 2750-1

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
CGI Impact Resistant Windows & Doors 3780 West 104th Street Hialeah, FL 33018	Series "CD4090A" Aluminum Inswing Side-Hinged Door w/ADA Sill (Full Fixed Lite/Full Single Hung) Configuration: XX Glazing: Monolithic Glass (Tempered) Frame: W-1829mm(72") H-2438mm(96") Panel: W-902mm(35.50") H-2413mm(95") DLO: W-622mm(24.50") H-2178mm(85.75")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 AAMA/WDMA/CSA 101/I.S.2/A440-08	Class R-PG35 1829 x 2438 (72 x 96)-LW SHD Design Pressure: ±1680 Pa (±35 psf) Water Penetration Resistance Test Pressure: 0 Pa (0.00 psf)

Product Tested By: Fenestration Testing Laboratory, Inc.
Report No: FTL-6646/FTL-6635/W-2014
Expiration Date: **December 31, 2025**

Administrator's Signature: _____


NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com