

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI011450.01
DATE: 12/22/2021
CERTIFICATION PROGRAM: Structural
COMPANY: Moss Supply
CODE: 206-1

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Moss Supply Company 5001 North Graham Street Charlotte, NC 28269	Series "3600" Vinyl Double Hung Window Configuration: X/X Glazing: Insulating Glass (Annealed) Frame: W-1219mm(48") H-2134mm(84") Sash: W-1165mm(45.88") H-1064mm(41.88") DLO: W-1094mm(43.06") H-994mm(39.13")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11	Class R-PG35 1219 x 2134 (48 x 84)-H Design Pressure: 1680 Pa (35 psf) Negative Design Pressure: 1920 Pa (40 psf) Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf) Canadian Air Infiltration/Exfiltration Level: A3

Product Tested By: Intertek, LLC
Report No: I7188.01-501-44
Expiration Date: **September 30, 2025**

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be 'M.D.', is written over the signature line.

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124

Email: nami@namiinc.com