

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015210-R3  
DATE: 04/13/2021  
CERTIFICATION PROGRAM: Structural  
COMPANY: Marco  
CODE: 2738-1  
REVISION DATE: 03/27/2026

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Marco Industries, Inc.</b> <b>4400 S. 72<sup>nd</sup> E. Avenue</b> <b>Tulsa, OK 74146-3650</b>	<b>“ The Python™ Ridge Pro 4' Vent”</b> <b>Polypropylene Roof Vent</b>

SPECIFICATION	PRODUCT RATING
<b>TAS 100(A)-95/23</b>	<b>Passed-110 mph Windspeed</b> <b>Passed-Water Resistance</b>
<b>ASTM E330-02/E330M-14</b>	<b>Design Pressure: +150/-60 psf</b>

Product Tested By: Fenestration Testing Laboratory, Inc.  
Report No: 6819/6831/S8365.01-801-44/T0288.01-801-18  
Expiration Date: **March 31, 2030**

Administrator's Signature: \_\_\_\_\_

A handwritten signature in black ink, appearing to be "M.D.", written over a horizontal line.

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**  
4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
Email: [nami@namniinc.com](mailto:nami@namniinc.com)

NOPC-03/30/2023