

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015480  
DATE: 01/10/2022  
CERTIFICATION PROGRAM: Fire  
COMPANY: Truitt & White  
CODE: 2807-1  
EXPIRATION DATE: 01/31/2026

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Truitt &amp; White Lumber Company, Inc.</b> <b>642 Hearst Avenue</b> <b>Berkeley, CA 94710</b>	<b>20 Minute Fiberglass Reinforced Faced</b> <b>Door w/Proprietary Core</b> <b>(Simulated Panel Type or Flush)</b>  Manufacturer Specific Fire Doors for Single Swing Installation in 20 Minute Locations  <b>Single Door Maximum Size: 3'0" x 6'8"</b> <b>Minimum Thickness: 1-3/4"</b>

SPECIFICATION	PRODUCT RATING
<b>NFPA 252 (2008)</b> <b>UL 10C (2009)</b> <b>CAN4 S104 (1985)</b>	<b>20 Minute-Positive Pressure</b> <b>With Hose Stream</b> <b>Category A - No Additional Edge Sealing</b> <b>Required</b>

TEST REPORT
<b>Intertek Test Report No: J20051379-231, 3084465, 317611MID-002, 3187023MID-002 &amp; 10035435MID-001</b>

Administrator's Signature: \_\_\_\_\_

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

[nami@namiinc.com](mailto:nami@namiinc.com)