

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015481-R1
DATE: 01/10/2022
CERTIFICATION PROGRAM: Fire
COMPANY: Truitt & White
CODE: 2807-1
EXPIRATION DATE: 01/31/2029
REVISION DATE: 02/04/2026

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Truitt & White Lumber Company, Inc. 642 Hearst Avenue Berkeley, CA 94710	Plastpro's 20 Minute Positive Pressure Fire Door Assemblies w/o Hose Stream Manufacturer Specific Fire Doors for Single or Double Swing Installation in 20 Minute Locations 1/2" Minimum Latch Throw Single or Double Swing Only Maximum Size: 3'0" x 8'0" Minimum Thickness: 1-3/4"

SPECIFICATION	PRODUCT RATING
NFPA 252 (1999) UL 10C (2009) UBC Standard 7-2 (1997)	20 Minute-Positive Pressure Without Hose Stream Category B Door-Additional Edge Seal Required <small>(unless specified in individual manufacturer's listing)</small> For Use in Category C Frame <small>(or may also be installed in Category C-Proprietary in accordance with individual manufacturer's listing)</small>

TEST REPORT
Intertek Test Report No: 3182549MID-005, 100644112MID-002, 100644112MID-004, 3178456MID-003, 3182549MID-005b, 100359215MID-010b

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway
Hayes, VA 23072

Tel: (804) 684-5124
nami@namiinc.com

NOPC 03/30/2023