

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015481  
DATE: 01/10/2022  
CERTIFICATION PROGRAM: Fire  
COMPANY: Truitt & White  
CODE: 2807-1  
EXPIRATION DATE: 01/31/2026

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Truitt &amp; White Lumber Company, Inc.</b>  <b>642 Hearst Avenue</b>  <b>Berkeley, CA 94710</b>	<b>Plastpro's 20 Minute Positive Pressure Fire Door Assemblies w/o Hose Stream</b>  Manufacturer Specific Fire Doors for Single or Double Swing Installation in 20 Minute Locations  1/2" Minimum Latch Throw Single or Double Swing Only  <b>Maximum Size: 3'0" x 8'0"</b> <b>Minimum Thickness: 1-3/4"</b>

SPECIFICATION	PRODUCT RATING
<b>NFPA 252 (1999)</b> <b>UL 10C (2009)</b> <b>UBC Standard 7-2 (1997)</b>	<b>20 Minute-Positive Pressure Without Hose Stream</b> <b>Category B Door-Additional Edge Seal Required</b> (unless specified in individual manufacturer's listing) <b>For Use in Category C Frame</b> (or may also be installed in Category C-Proprietary in accordance with individual manufacturer's listing)

TEST REPORT
<b>Intertek Test Report No: 3182549MID-005, 100644112MID-002, 100644112MID-004, 3178456MID-003, 3182549MID-005b, 100359215MID-010b</b>

Administrator's Signature: \_\_\_\_\_

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

[nami@namiinc.com](mailto:nami@namiinc.com)