

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015492
DATE: 01/10/2022
CERTIFICATION PROGRAM: Fire
COMPANY: Truitt & White
CODE: 2807-1
EXPIRATION DATE: 01/31/2026

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Truitt & White Lumber Company, Inc. 642 Hearst Avenue Berkeley, CA 94710	20-Minute Fiberglass Fire Door Manufacturer Specific Fire Doors for Single Swing Installation in 20 Minute Locations 1/2" Minimum Latch Throw Single Swing Only Maximum Size: 3'0" x 6'8" Minimum Thickness: 1-3/4"

SPECIFICATION	PRODUCT RATING
NFPA 252 (2017) UL 10C (2016) CAN/ULC S104 (2015)	20 Minute-Neutral/Positive Pressure With Hose Stream Category B - Additional Edge-Sealing System Required

TEST REPORT
Intertek Test Report No: 103550846MID-003, G103550846

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "M.D.", is written over the signature line.

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com