

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015496  
DATE: 01/10/2022  
CERTIFICATION PROGRAM: Fire  
COMPANY: Truitt & White  
CODE: 2807-1  
EXPIRATION DATE: 01/31/2026

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Truitt &amp; White Lumber Company, Inc.</b>  <b>642 Hearst Avenue</b>  <b>Berkeley, CA 94710</b>	<b>"ABS 20-Minute"</b>  <b>Routed Particleboard Fire Door</b>  Manufacturer Specific Fire Doors for Single Swing Installation in 20-Minute Locations  1/2" Minimum Latch Throw Single Swing Only  <b>20-Minute Single Maximum Size: 3'0" x 8'0"</b> <b>Minimum Thickness: 1-3/4"</b>

SPECIFICATION	PRODUCT RATING
<b>NFPA 252 (2012)</b> <b>UL 10C (2009)</b>	<b>20 Minute-Positive Pressure</b> <b>Without Hose Stream</b> <b>Category B - Additional Edge-Sealing</b> <b>System Required</b>

TEST REPORT
<b>Intertek Test Report No: 3107376COQ-004, 3169105, 3043898, 102245905, 104375792</b>

Administrator's Signature:  \_\_\_\_\_

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**  
4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
[nami@namiinc.com](mailto:nami@namiinc.com)