

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI015502  
**DATE:** 01/24/2022  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Lepage  
**CODE:** 422-1

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Lepage Millwork</b> <b>141 Chemin des Raymond</b> <b>Riviere-du-Loup, Quebec G5R 4L9</b>	<b>Series "Clad Casement (C-100) Impact</b> <b>Series 2 1/4" Sash"</b> <b>Aluminum Clad Wood Casement Window</b>  Configuration: X Glazing: IG-Int.-4mm Annealed Glass/Ext.-Laminate- 4mm Annealed Glass/0.090" Sentry Glass Plus Interlayer/4mm Annealed Glass  Frame: W-914mm(36") H-1829mm(72") Vent: W-852mm(33.56") H-1767mm(69.56") DLO: W-759mm(29.88") H-1673mm(65.88")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-17</b> <b>ASTM E1886-02/04/05/13a</b> <b>ASTM E1996-02/04/06/09/12a/14a</b>	<b>Class CW-PG50 914 x 1829 (36 x 72)-C</b> <b>Design Pressure: ±2400 Pa (±50 psf)</b> Water Penetration Resistance Test Pressure: 720 Pa (15.04 psf) <b>Wind Zone 3-Missile Level D</b> <b>Large Missile Impact Rated</b>

Product Tested By: National Certified Testing Laboratories  
Report No: NCTL-110-24762-1/NCTL-110-24762-2  
Expiration Date: **December 31, 2025**

Administrator's Signature: \_\_\_\_\_

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072

Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)