

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI015504  
**DATE:** 01/24/2022  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Lepage  
**CODE:** 422-1

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

| COMPANY NAME AND ADDRESS  | PRODUCT DESCRIPTION  |
|---|--|
| <b>Lepage Millwork</b><br><b>141 Chemin des Raymond</b><br><b>Riviere-du-Loup, Quebec G5R 4L9</b> | <b>Series "2 1/4" Natural Fixed Sash</b><br><b>Impact Series"</b><br><b>Wood Fixed Window</b><br><br>Configuration: O<br>Glazing: IG-Int.-4mm Annealed Glass/Ext.-Laminate-4mm Annealed Glass/0.090" Sentry Glass Plus Interlayer/4mm Annealed Glass<br><br>Frame: W-1829mm(72") H-1829mm(72")<br>DLO: W-1664mm(65.50") H-1664mm(65.50") |

| SPECIFICATION   | PRODUCT RATING   |
|---|--|
| <b>AAMA/WDMA/CSA 101/I.S.2/A440-17</b><br><b>ASTM E1886-02/04/05/13a</b><br><b>ASTM E1996-02/04/06/09/12a/14a</b> | <b>Class CW-PG50 1829 x 1829 (72 x 72)-FW</b><br><b>Design Pressure: ±2400 Pa (±50 psf)</b><br>Water Penetration Resistance Test Pressure: 720 Pa (15.04 psf)<br><b>Wind Zone 3-Missile Level D</b><br><b>Large Missile Impact Rated</b> |

Product Tested By: National Certified Testing Laboratories  
Report No: NCTL-110-24765-1/NCTL-110-24765-2  
Expiration Date: **December 31, 2025**

Administrator's Signature: \_\_\_\_\_

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072

Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)