

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015506-R1
DATE: 01/25/2022
CERTIFICATION PROGRAM: Fire
COMPANY: Boise Cascade
CODE: 2820-1
REVISION DATE: 03/05/2024
EXPIRATION DATE: 01/31/2026

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

| COMPANY NAME AND ADDRESS | PRODUCT DESCRIPTION |
|---|--|
| Boise Cascade 1020 West 3265 Street Salt Lake City, UT 84119 | 20 Minute Positive Pressure Steel Fire Door Assemblies w/o Hose Stream Manufacturer Specific Fire Doors for Single Swing Installation in 20 Minute Locations 1/2" Minimum Latch Throw Single Swing Only Maximum Size: 3'0" x 7'0" Minimum Thickness: 1-3/4" |

| SPECIFICATION | PRODUCT RATING |
|--|--|
| NFPA 252 (1999) UL 10C (1998) UL 10B (1997) UBC Standard 7-2 (1997) | 20 Minute-Positive Pressure Without Hose Stream Category B Door-Additional Edge Seal Required (unless specified in individual manufacturer's listing) For Use in Category C Frame (or may also be installed in Category C-Proprietary in accordance with individual manufacturer's listing) |

TEST REPORT

Intertek Test Report No: 3042535-1, 3042535-2
NAMI Waiver of Retest: W-1653

A handwritten signature in black ink, appearing to be "Shirley", written over a horizontal line.

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072

Tel: (804) 684-5124

nami@namiinc.com

NOPC 03/30/2024