

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015507
DATE: 01/25/2022
CERTIFICATION PROGRAM: Fire
COMPANY: Boise Cascade
CODE: 2820-1
EXPIRATION DATE: 01/31/2026

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Boise Cascade 1020 West 3265 Street Salt Lake City, UT 84119	20 Minute Category C Proprietary Wood Door Frames Manufacture Specific Fire Door Frames for Single Swing Only Installation in 20 Minute Locations Single Door Maximum Size: 3'6" x 7'0" Minimum Thickness: 3-3/4"

SPECIFICATION	PRODUCT RATING
UL 10C (1998) UBC Standard 7-2 (1997) UBC Standard 7-2 (1994)	20 Minute-With & Without Hose Stream Neutral Pressure Category C- Proprietary Frame

TEST REPORT
Warnock Hersey Test Report No: WHI-495-0509 Intertek Test Report No(s): 3746699, 8772599, 3028781, 3035264, 3048460 Priest & Assoc. Engineering Evaluation No: 10260 NAMI Waiver of Retest: W-1747

Administrator's Signature:  _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com