

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015509-R1  
DATE: 01/25/2022  
CERTIFICATION PROGRAM: Fire  
COMPANY: Boise Cascade  
CODE: 2820-1  
REVISION DATE: 03/05/2024  
EXPIRATION DATE: 01/31/2026

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namincertification.com](http://www.namincertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Boise Cascade</b> <b>1020 West 3265 Street</b> <b>Salt Lake City, UT 84119</b>	<b>20 Minute Fiberglass Reinforced Faced</b> <b>Door w/Proprietary Core</b> <b>(Simulated Panel Type or Flush)</b>  Manufacturer Specific Fire Doors for Single Swing Installation in 20 Minute Locations  <b>Single Door Maximum Size: 3'0" x 6'8"</b> <b>Minimum Thickness: 1-3/4"</b>

SPECIFICATION	PRODUCT RATING
<b>NFPA 252 (2008)</b> <b>UL 10C (2009)</b> <b>CAN4 S104 (1985)</b>	<b>20 Minute-Positive Pressure</b> <b>With Hose Stream</b> <b>Category A - No Additional Edge Sealing</b> <b>Required</b>

TEST REPORT
<b>Intertek Test Report No: J20051379-231, 3084465, 317611MID-002, 3187023MID-002 &amp; 10035435MID-001</b>

Administrator's Signature: \_\_\_\_\_

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**

**4794 George Washington Memorial Highway**

**Hayes, VA 23072**

**Tel: (804) 684-5124**

**[nami@namiinc.com](mailto:nami@namiinc.com)**

NOPC 03/30/2024