NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO:	**NI015509-R3**
DATE:	**01/25/2022**
CERTIFICATION PROGRAM:	**Fire**
COMPANY:	**Boise Cascade**
CODE:	**2820-1**
REVISION DATE:	**06/18/2026**
EXPIRATION DATE:	**01/31/2036**

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Boise Cascade **1020 West 3265 Street** **Salt Lake City, UT 84119**	**20 Minute Fiberglass Reinforced Faced Door w/Proprietary Core (Simulated Panel Type or Flush)** Manufacturer Specific Fire Doors for Single Swing Installation in 20 Minute Locations **Single Door Maximum Size: 3'0" x 6'8"** **Minimum Thickness: 1-3/4"**

SPECIFICATION	PRODUCT RATING
NFPA 252 (2008) **UL 10C (2009)** **CAN4 S104 (1985)**	**20 Minute-Positive Pressure With Hose Stream** **Category A - No Additional Edge Sealing Required**

TEST REPORT
Intertek Test Report No: J20051379-231, 3084465, 317611MID-002, 3187023MID-002 & 10035435MID-001

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com