

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015509
DATE: 01/25/2022
CERTIFICATION PROGRAM: Fire
COMPANY: Boise Cascade
CODE: 2820-1
EXPIRATION DATE: 01/31/2026

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Boise Cascade 1020 West 3265 Street Salt Lake City, UT 84119	20 Minute Fiberglass Reinforced Faced Door w/Proprietary Core (Simulated Panel Type or Flush) Manufacturer Specific Fire Doors for Single Swing Installation in 20 Minute Locations Single Door Maximum Size: 3'0" x 6'8" Minimum Thickness: 1-3/4"

SPECIFICATION	PRODUCT RATING
NFPA 252 (2008) UL 10C (2009) CAN4 S104 (1985)	20 Minute-Positive Pressure With Hose Stream Category A - No Additional Edge Sealing Required

TEST REPORT
Intertek Test Report No: J20051379-231, 3084465, 317611MID-002, 3187023MID-002 & 10035435MID-001

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

nami@namiinc.com