

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015511
DATE: 01/27/2022
CERTIFICATION PROGRAM: Fire
COMPANY: Boise Cascade
CODE: 2820-1
EXPIRATION DATE: 01/31/2026

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

| COMPANY NAME AND ADDRESS | PRODUCT DESCRIPTION |
|---|---|
| Boise Cascade 1020 West 3265 Street Salt Lake City, UT 84119 | 20 Minute Positive Pressure Flush or Molded Interior Side-Hinged Door w/Wheatboard Core Manufacturer Specific Fire Doors for Single Swing Installation in 20 Minute Locations 1/2" Minimum Latch Throw Single Swing Only Maximum Size: 3'0" x 8'0" Minimum Thickness: 1-3/4" |

| SPECIFICATION | PRODUCT RATING |
|---|---|
| NFPA 252 (1999) UL 10(b) (1997/2009) CAN4-S104 (1985) UBC Standard 7-2 (1994/1997) UL 10(c) (2009) | 20 Minute-Positive Pressure With Hose Stream Category B Door-Additional Edge Seal Required For Use in Category C Frame (or may also be installed in Category C-Proprietary in accordance with individual manufacturer's listing) |

| TEST REPORT |
|--|
| Intertek Test Report No: 3137714COQ-008 |

Administrator's Signature: 

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

nami@namiinc.com