

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015533
DATE: 02/03/2022
CERTIFICATION PROGRAM: Structural
COMPANY: Edgewater
CODE: 1779-1

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Edgewater Door Acquisition Company, LLC 175 North Western Avenue Neenah, WI 54956	Series "EH" Opaque FRP Out-Swing Side-Hinged Door Assembly Configuration: X Frame: W-1321mm(52") H-2489mm(98") Panel: W-1216mm(47.88") H-2426mm(95.5")

SPECIFICATION	PRODUCT RATING
ASTM E330/E330M-21 ASTM E331-16 ASTM E283/E283M-19 ASTM E1886-19/E1996-20	Design Pressure: +70/-70 psf Water Penetration Resistance Test Pressure: 0 Pa (0 psf) Missile Level D

Product Tested By: Intertek, PLC
Report No: 104711107MID-013
Expiration Date: November 30, 2025

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com