

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015536.01  
DATE: 02/08/2022  
CERTIFICATION PROGRAM: Structural  
COMPANY: Continental Glass  
CODE: 2103-1

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Continental Glass Systems, LLC</b> <b>325 West 74 Place</b> <b>Hialeah, FL 33014</b>	<b>Series "3200"</b> <b>Aluminum Window Wall System</b>  Configuration: OOO Glazing IG - 1/4" Tempered Glass/1/4" Heat Strengthened Glass/0.090" SG Kuraray Interlayer/1/4" Heat Strengthened Glass  Frame: W-46355mm(182.5") H-3658mm(144") DLO: W-1461mm(57.5") H-3505mm(138")

SPECIFICATION	PRODUCT RATING
<b>TAS 201/202/203-94</b>	<b>Design Pressure: ±3352 Pa (±70 psf)</b> <b>Small Missile Impact Rated</b> <b>Large Missile Impact Rated</b> <b>Water Test Pressure: 862 Pa (18 psf)</b>

Product Tested By: Intertek  
Report No: BT-CON-21-011/BT-CON-21-016  
Expiration Date: **June 30, 2025**

Administrator's Signature: \_\_\_\_\_ 

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**  
4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
E-Mail: [nami@namiinc.com](mailto:nami@namiinc.com)