

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015539-R1
DATE: 02/28/2022
CERTIFICATION PROGRAM: Fire
COMPANY: Caldera
CODE: 2830-1
REVISION DATE: 08/01/2024
EXPIRATION DATE: 02/28/2026

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Boise Cascade Millwork Products 2980 South Wise Way Boise, ID 83716	<p style="text-align: center;">20 Minute Positive Pressure</p> <p style="text-align: center;">Molded Simulated Panel Side-Hinged</p> <p style="text-align: center;">Side-Hinged Door Assembly</p> <p style="text-align: center;">Manufacturer Specific Fire Doors for Single Swing or Standard Pairs Installation in 20 Minute Locations</p> <p style="text-align: center;">1/2" Minimum Latch Throw Single Swing or Standard Pairs Only</p> <p style="text-align: center;">Single Swing Maximum Size: 3'0" x 8'0" Standard Pairs Maximum Size: 6'0" x 8'0" Minimum Thickness: 1-3/4"</p>

SPECIFICATION	PRODUCT RATING
NFPA 252 (1999) UL 10(b) (2009) CAN4-S104 (1985)(2010) UL 10(c) (2009)	<p>20 Minute-Positive Pressure</p> <p>With Hose Stream</p> <p>Category B Door-Additional Edge Seal</p> <p>Required</p> <p>For Use in Category C Frame</p> <p>(or may also be installed in Category C-Proprietary in accordance with individual manufacturer's listing)</p>

TEST REPORT
Intertek Test Report No: 3192291COQ-005, 100211525COQ-001, 100553244COQ-002, 100581395MID-001, 101432263COQ


 Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway
 Hayes, VA 23072
 Tel: (804) 684-5124
nami@namiinc.com