

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015540-R1  
DATE: 02/28/2022  
CERTIFICATION PROGRAM: Fire  
COMPANY: Caldera  
CODE: 2830-1  
REVISION DATE: 08/01/2024  
EXPIRATION DATE: 02/28/2026

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Boise Cascade Millwork Products</b> <b>2980 South Wise Way</b> <b>Boise, ID 83716</b>	<b>Jeld Wen Premium 20 Minute Neutral Pressure Fiberglass Side-Hinged Door Assemblies</b>  Manufacturer Specific Fire Doors for Single Swing Installation in 20 Minute Locations  1/2" Minimum Latch Throw Single Swing and Pairs Allowed  <b>Single Swing Maximum Size: 3'0" x 8'0"</b> <b>Minimum Thickness: 1-3/4"</b>  <b>Pairs Maximum Size: 6'0" x 6'8"</b> <b>Minimum Thickness: 1-3/4"</b>

SPECIFICATION	PRODUCT RATING
<b>NFPA 252 (2008)</b> <b>UL 10B (2008/2009)</b> <b>CAN/ULC S104 (2010)</b>	<b>20 Minute-Neutral Pressure With Hose Stream</b> <b>Category B - Additional Edge Sealing Required</b>

TEST REPORT
<b>Intertek Test Report No: 3091617, 3145981MID-005b, 3153159MID-007, 100211525COQ-001</b>

Administrator's Signature: 

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

[nami@namiinc.com](mailto:nami@namiinc.com)

NOPC-03/30/2023