


NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015550
DATE: 02/28/2022
CERTIFICATION PROGRAM: Fire
COMPANY: Caldera
CODE: 2830-1
EXPIRATION DATE: 02/28/2026

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Caldera Industries, LLC 2980 South Wise Way Boise, ID 83716	"ABS 20-Minute" Routed Particleboard Fire Door Manufacturer Specific Fire Doors for Single Swing Installation in 20-Minute Locations 1/2" Minimum Latch Throw Single Swing Only 20-Minute Single Maximum Size: 3'0" x 8'0" Minimum Thickness: 1-3/4"

SPECIFICATION	PRODUCT RATING
NFPA 252 (2012) UL 10C (2009)	20 Minute-Positive Pressure Without Hose Stream Category B - Additional Edge-Sealing System Required

TEST REPORT
Intertek Test Report No: 3107376COQ-004, 3169105, 3043898, 102245905, 104375792

Administrator's Signature:  _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

nami@namiinc.com