

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI014453.01  
**DATE:** 03/14/2022  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Sunset Windows  
**CODE:** 2348-1

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Sunset Windows and Doors, LLC</b> <b>910 Warehouse Road, Unit 110104</b> <b>Orlando, FL 32803</b>	<b>Series "V-750"</b> <b>Vinyl Fixed Window</b>  Configuration: O Glazing: Mono-3/16" Heat Strengthened Glass/0.090 SGP by Kuraray/3/16" Heat Strengthened Glass IG-3/16" Tempered Glass/ 3/16" Heat Strengthened Glass/0.090 SGP by Kuraray/3/16" Heat Strengthened Glass Glazing: Mono-3/16" Heat Strengthened Glass/0.090 Trosifol by Kuraray/3/16" Heat Strengthened Glass IG-3/16" Tempered Glass/ 3/16" Heat Strengthened Glass/0.090 PVB by Kuraray/3/16" Heat Strengthened Glass  Frame: W-1524mm(60") H-2438mm(96") DLO: W-1399mm(55.08") H-2287mm(90.03")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-17</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-11</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-08</b>	<b>Class AW-PG65 1524 x 2438 (60 x 96)-FW</b> <b>Design Pressure: ±3120 Pa (±65 psf)</b> <b>Water Penetration Resistance Level: 960 Pa (20.0 psf)</b>

Product Tested By: National Certified Testing Laboratories  
Report No: NCTL-210-4227-01/NCTL-210-4227-01A  
Expiration Date: August 31, 2025

Administrator's Signature: \_\_\_\_\_  


**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**  
4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
Email: [nami@namiinc.com](mailto:nami@namiinc.com)