

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014453.03
DATE: 03/14/2022
CERTIFICATION PROGRAM: Structural
COMPANY: Sunset Windows
CODE: 2348-1

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Sunset Windows and Doors, LLC 910 Warehouse Road, Unit 110104 Orlando, FL 32803	Series "V-750" Vinyl Fixed Window Configuration: O Glazing: Mono-3/16" Heat Strengthened Glass/0.090 SGP by Kuraray/3/16" Heat Strengthened Glass IG-3/16" Tempered Glass/ 3/16" Heat Strengthened Glass/0.090 SGP by Kuraray/3/16" Heat Strengthened Glass Frame: W-1524mm(60") H-2438mm(96") DLO: W-1399mm(55.08") H-2287mm(90.03")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 ASTM E1886-12/13a ASTM E1996-12a/14a TAS-201/202/203-94	Class AW-PG65 1524 x 2438 (60 x 96)-FW Design Pressure: ±3120 Pa (±65 psf) Water Penetration Resistance Level: 960 Pa (20.0 psf) Wind Zone 4-Missile Level D Large Missile Impact Rated

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-210-4227-01/NCTL-210-4227-01A
Expiration Date: August 31, 2025

Administrator's Signature: _____


NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com